



**EVERSAFE**<sup>®</sup>  
Your solution to FIRE SAFETY



# EVERSAFE NAF S 227<sup>®</sup>

(HFC 227ea + D-LIMONENE)

UL LISTED TOTAL FLOODING  
EXTINGUISHING SYSTEMS  
AN ALTERNATIVE TO FM200



**TENAGA  
NASIONAL BERHAD**

# EVERSAFE NAF S 227<sup>®</sup>

## EVERSAFE NAF S 227<sup>®</sup> SYSTEM COMPONENTS



Discharge Hose



Release Line Teflon Flexible Hoses



Non Retune Valve



Manual / Pneumatic Release Device



Nozzle



Discharge Actuation



Twin Flashing Light



Backup Battery



Alarm Bell



Heat Detector



Smoke Detector



Optical Smoke With Thermal Detector



Power Line Lightning Arrestor 240vdc



Signal Line Lightning Arrestor 24vdc



Evacuate Signal



Manual Call Point/ Manual Discharge Station



Control Panel



Abort Station

# EVERSAFE NAF S 227<sup>®</sup>

## EVERSAFE NAF S 227<sup>®</sup> CYLINDER SPECIFICATIONS




V-20      V-25      V-40      V-65

### Cylinder Size

Part Number	Cylinder Size	Valve Outlet Size	Cylinder Height (±10mm)	Cylinder Diameter (mm)	Approval	Approval Number
SH70027409	13.4 L	V20	1140	140	UL	UL-2166
SH70027408	26.8 L	V20	1010	229		
SH70027407	40.2 L	V25	1320	229		
SH70027412	67.5 L	V25	1585	267		
SH70027405	75.0 L	V40	1750	267		
SH70027404	100.0 L	V40	1320	357		
SH70027403	120.0 L	V40	1560	360		
SH70027413	142.0 L	V65	1345	406		
SH70027414	175.0 L	V65	1310	460		
SH70027415	240.0 L	V65	1939	460		

## EVERSAFE NAF S 227<sup>®</sup> SYSTEM APPROVAL CERTIFICATES





## Agency in Vietnam

### MINH BAO Co., Ltd

128 Luong The Vinh St., Tan Thoi Hoa Ward,  
Tan Phu District, Ho Chi Minh City

**Tel:** 08 3961 1082

**Fax:** 08 3876 2198

**Email:** [minhbao@minhbao.com.vn](mailto:minhbao@minhbao.com.vn)

**Web:** [www.minhbao.com.vn](http://www.minhbao.com.vn)

